

Certificate of Conformity

No.: PD/0134/2023

Applicant:	JIANGSU ACREL ELECTRICAL MANUFACTURING. CO., LTD.
Name, address:	No.5, Dongmeng Road, Nanzha, Jiangyin, Jiangsu, China
Manufacturer:	JIANGSU ACREL ELECTRICAL MANUFACTURING. CO., LTD.
Name, address:	No.5, Dongmeng Road, Nanzha, Jiangyin, Jiangsu, China
Product:	Single phase Energy Meter
Type/Models:	ADL200N-CT
Tested Standard(s):	EN IEC 61326-1:2021, CISPR 32:2019, EN 61010-1:2010/A1:2019

The product conforms to the requirements of (see Tested Standards) which is harmonized with Low Voltage Directive:

2014/35/EU and Electromagnetic Compatibility Directive: 2014/30/EU.

The assessment of conformity was based on:

- evaluation of the technical documentation of the product as mentioned above

- results contained in test report no.: JLHG-FA230441, JLHG-NE230351

Validity period: from 16/Aug/2023 to 15/Aug/2028

This certificate applies only to product samples with the same characteristics and complying with the above-mentioned requirements as the samples submitted for assessment.

This certificate has been issued in accordance with voluntary certification programme DPCW-01 (type 1a by EN ISO/IEC 17067).

Chief Executive Officer: Ben XU	
Rum	



Warsaw, 16/Aug/2023



Intercertglobal sp. z o.o. Krucza 16/22, 00-526 Warsaw, Poland

Tel.:+48 780 142 399 Email: sekretariat@intercertglobal.com

intercertglobal.com